



Certificate of Compliance

Certificate: 1730306

Master Contract: 159323

Project: 1730306

Date Issued: November 21, 2005

Issued to: Varec Inc.
5834 Peachtree Corners E
Norcross, GA 30092
USA

Attention: Mr. Warren Sutcliffe

The products listed below are eligible to bear the CSA Mark shown



Issued by: Peter Smith CEI

Authorized by: Patricia Pasemko
Operations Manager

PRODUCTS

CLASS - 2258 02 - PROCESS CONTROL EQUIPMENT - For Hazardous Locations

Class I, Div 2, Groups A, B, C and D:

- Model 8130 RTUxx2 Termination Board; input rated 120/240 Vac, 50/60 Hz, 500 mA max; 18-36 Vdc, 300 mA max; provided with I/O Expansion Modules, Models 8201, 8202-0, 8203, 8204, 8205-0, 8206, 8210 and 8211 installed per Installation Drawing 012422; Temp. Code T3C; Max. Ambient 70 Deg C.

APPLICABLE REQUIREMENTS

CSA Std C22.2 No. 142-M1987	-	Process Control Equipment
CSA Std C22.2 No. 213-M1987	-	Non-Incendive Electrical Equipment for Use in Class I, Division 2 Hazardous Locations



CSA INTERNATIONAL

Page 2

Certificate: 1730306

Master Contract: 159323

MARKINGS

Submittor's name and /or file number
Model number
Serial number
Electrical rating
Hazardous locations designation
CSA Mark
Max ambient
Caution re substitution of components
Caution re disconnection of equipment
Reference to installation drawing



CSA INTERNATIONAL

Supplement to Certificate of Compliance

Certificate: 1730306

Master Contract: 159323

*The products listed, including the latest revision described below,
are eligible to be marked in accordance with the referenced Certificate.*

Product Certification History

Project	Date	Description
1730306	2005/11/21	Transfer Model 8130 RTU from MC 176244 (LR 66529-16) to Varec MC 159323 (LR 40894) and delist from LR 66529.