



CSA INTERNATIONAL

# Certificate of Compliance

**Certificate:** 1803857

**Master Contract:** 159323

**Project:** 1803857

**Date Issued:** 2006/08/09

**Issued to:** Varec Inc.

5834 Peachtree Corners E  
Norcross, GA 30092  
USA  
Attention: Warren Sutcliffe

*The products listed below are eligible to bear the CSA Mark shown*



**Issued by:** Rob Kohuch E.I.T.

**Authorized by:** Patricia Pasemko, Operations  
Manager

## **PRODUCTS**

**CLASS 2258 02** - PROCESS CONTROL EQUIPMENT - For Hazardous Locations

Class I, Division 1, C and D. Maximum Ambient 85° C, Temp Code T5. Enclosure Type 4.

Model 2900 Float and Tape Transmitter, Input: 20-65/110/220 Vac, 500 mW, 50/60Hz or 20-65 Vdc, 0.2A.

## **APPLICABLE REQUIREMENTS**

CSA Standard C22.2 No 0 M91 - General Requirements Canadian Electrical Code Part II.

CSA Standard C22.2 No 0.4 04 - Bonding of Electrical Equipment.



**Certificate:** 1803857

**Master Contract:** 159323

**Project:** 1803857

**Date Issued:** 2006/08/09

---

CSA Standard C22.2 No 25-1966 - Enclosures for use in Class II, Groups E, F, and G.

CSA Standard C22.2 -30-M1986 - Explosion-Proof Enclosures for Use in Class I Hazardous Locations

CSA Standard C22.2 No 94-M91 - Special Purpose Enclosures.

CSA Standard C22.2 -142-M1987 - Process Control Equipment



CSA INTERNATIONAL

## *Supplement to Certificate of Compliance*

Certificate: 1803857

Master Contract: 159323

*The products listed, including the latest revision described below, are eligible to be marked in accordance with the referenced Certificate.*

### Product Certification History

---

Project	Date	Description
1803857	2006/08/09	Original Certification of 2900 Float Transmitter based on FM report 3024246.